



Washington Global PCS - Lead in Water Test Results



FY20 Filter Test

Less than 5 ppb - Devices Requiring No Remediation

Charter Campus Name	Water Source ID	Device Type	Floor	Device Location	Location Identifier		Water Filter ID	Date Analyzed	Draw A Sample ID	FT Final Results - Draw A (ppb)	Draw B Sample ID	FT Final Results - Draw B (ppb)
					High/Low	Left/Mid/Right						
Washington Global PCS	WS-088-001	Food Prep Sink	1	In kitchen 102			WF-082019-088001-02	11/22/2019	FT-FY20-082019-088001-A	4.4	FT-FY20-082019-088001-B	<1
Washington Global PCS	WS-088-002	Health Suite	1	In health suite 105			WF-082019-088002-02	11/22/2019	FT-FY20-082019-088002-A	2.7	FT-FY20-082019-088002-B	<1
Washington Global PCS	WS-088-003	Cooler	1	In hallway adjacent to room 100A	High	Left	WF-082019-088003-02	11/22/2019	FT-FY20-082019-088003-A	<1	FT-FY20-082019-088003-B	<1
Washington Global PCS	WS-088-004	Cooler	1	In hallway adjacent to room 100A	Low	Right	WF-082019-088004-02	11/22/2019	FT-FY20-082019-088004-A	<1	FT-FY20-082019-088004-B	<1
Washington Global PCS	WS-088-006	Cooler	2	In hallway adjacent to room 200B	High	Left	WF-082019-088006-02	11/22/2019	FT-FY20-082019-088006-A	<1	FT-FY20-082019-088006-B	<1
Washington Global PCS	WS-088-007	Cooler	2	In hallway adjacent to room 200B	Low	Right	WF-082019-088007-02	11/22/2019	FT-FY20-082019-088007-A	<1	FT-FY20-082019-088007-B	<1
Washington Global PCS	WS-088-010	Cooler	3	In hallway adjacent to room 300B	High	Left	WF-082019-088010-02	11/22/2019	FT-FY20-082019-088010-A	<1	FT-FY20-082019-088010-B	<1
Washington Global PCS	WS-088-011	Cooler	3	In hallway adjacent to room 300B	Low	Right	WF-082019-088011-02	11/22/2019	FT-FY20-082019-088011-A	<1	FT-FY20-082019-088011-B	<1
Washington Global PCS	WS-088-014	Cooler	4	In hallway adjacent to room 400B	Low	Right	WF-082019-088014-02	11/22/2019	FT-FY20-082019-088014-A	<1	FT-FY20-082019-088014-B	<1